

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE.

No. 1261Date : 01.7.26

It is certified that an inspection team headed by SRI SHASHI
KANT KUMAR. CHEMIST (Name of Officers
with designation) from POHO DIVISION SHEIKHPURA (Name of
Department/Office) inspected the GYAN NIKETAN RESIDENTIAL
SCHOOL, BARBIGHA. (Name & Address of
the School) on 12/06/26 and found that the GYAN NIKETAN
RESIDENTIAL SCHOOL BARBIGHA. (Name of school) has safe
drinking water facilities for the students and members of staff of the institution and is maintaining
the hygienic sanitation condition in the school building & the campus as per the norms
prescribed by the Central/State/U.T Govt.

The above valid for a period of SIX MONTHS.

Signature with Seal : [Signature]
Name : [Name]
Designation : [Designation]

To

Gyan Niketan Residential
School Barbigha (Sheikhpura)
Near Regional Hospital Barbigha
(Name & Address of the Institution)

[Signature]
30/6/26



Government of Bihar
Public Health Engineering Department
District Level Water Testing Laboratory
Sheikhpura, Near Jakhraj Asthan,
Dist-Sheikhpura, Bihar Pin-811105
Email id-shashikant88kumar@gmail.com. Mob:- 9006336473



DOC No: SHP\SAMP\05\00

TEST REPORT

Name & Address Of the Customer G.N.R Barbigha School Block-Barbigha Panchayat-Nagar Parisad Village- Barbigha G.N.R Barbigha School	URL NO- Report No. Date Sample No. Sample Description Sample Mark/ Location Sample Collected On Sampling Plan & Method Sample Submitted On Date of Performance (s) Ref No. Date	TC154332500000044F : SHP/W/26-27/R/44 : 22.06.2026 : SHP/W/26-27/44 : Drinking Water : G.N.R Barbigha School : 12.06.2026 : IS 17614 Part-1 2021 : 12.06.2026 : 12.06.2026 to 22.05.2026 :-
--	---	---

Analysis Result

SL No.	Test Parameter	Test Method	IS 10500:2012Amd. 1 & 2		Result
			Acceptable Limit	Permissible Limit	
1	pH Value in 25°C	IS 3025(Part 11) : 2022	6.5.8.5	No Relaxation	7.5
2	Turbidity in NTU	IS 3025 (Part 10) :2024	1	5	1.0
3	TDS in mg/l	IS 3025(Part 16) : 2023	500	2000	468
4	Total Hardness in mg/l	IS 3025(Part 21) : 2019	200	600	317.52
5	Calcium in mg/l	IS 3025(Part 40) : 2024	75	200	86.46
6	Magnesium in mg/l	APHA 24th Edition -3500- Mg B; 2023	30	100	22.84
7	Iron in mg/l	APHA 24th Edition -3500-Fe Method B; (Phenanthroline Method) : 2023	1	No Relaxation	0.01
8	Chloride in mg/l	IS 3025(Part 32) : 2025	250	1000	45.64
9	Total Alkalinity in mg/l	IS 3025(Part 23) : 2023	200	600	76.76
10	Colour in HU	IS 3025 (Part 4) : 2021	5	15	<1
11	Odour	IS 3025 (Part 5) : 2018	Agreeable	Agreeable	Agreeable
12	Taste	IS 3025 (Part 8) : 2023	Agreeable	Agreeable	Agreeable
13	Fluoride mg/l	APHA 24th Edition -4500F C; 2023	1	1.5	0.25

For District Level Water Testing Laboratory Sheikhpura
Reviewed & Authorized By



End of Report

- The results relate only to the items(s) tested.
- This Test Report shall not reproduced without the permission of District Level Water Testing Laboratory, Sheikhpura.
- The reserved part of sample(s), except perishable sample(s), shall be retained for 15 day's from the date of issue of the Test report.